

**Monterey County Health Department  
Environmental Health Division  
Emergency Response Incident Report  
Proposition 65 Notification**

**MCHD #** 23 - 068  
**CM024-00145**

Incident Date: <b>8/11/23</b>		Incident Time: <b>3:30 PM</b>	
Incident Type:	<input type="checkbox"/> Hazardous Material <input type="checkbox"/> Suspected Bioterrorist Threat <input type="checkbox"/> Clandestine Drug Lab	<input type="checkbox"/> Sewage <input type="checkbox"/> Restaurant Fire <input checked="" type="checkbox"/> Other: <b>FR3 Oil/Insulating Oil</b>	
Time Notified: <b>8/12/23 at 11:52 AM</b>		Time Completed:	
Location: <b>Blackie Rd. (2,000 Feet South)</b>		City: <b>Castroville</b>	
Hazardous Material:		Quantity: <b>12 Gallons</b>	
Physical Properties: <b>Liquid</b>		Physical / Health Hazards:	
Land Use: <b>N/A</b>	Direct/Constructed Connections Found: <b>No</b>	Entered Storm Drain System/Receiving Waters: <b>No</b>	
Environment Affected: <b>Ag canal</b>		Weather / Temperature: <b>Sunny 70 °F</b>	
Type of Container: <b>Electric Transforme</b>			
First Responder / Agency on Scene: <b>N/A</b>			
Incident Commander:		Agency / Telephone: ( ) -	
Other Responding Personnel / Agencies / Telephone:			
( ) -		( ) -	

Source Investigation Conducted? <b>Yes</b>		Source Identified? <b>Yes</b>	
Responsible Party Information: <input type="checkbox"/> - <b>Invoice</b>	<b>PG&amp;E, c/o Caren Wilhoit</b> Mailing Address: <b>401 Work St.</b> , City, State, Zip Code: <b>Salinas, CA 93901</b> (408)931-1301 , E-Mail: <b>C2WB@pge.com</b>		
Vehicle Information:	O.E.S. Control #: <b>23-5148</b>	NRC #:	

<b>Other Notifications:</b>				
<input type="checkbox"/> RWQCB	<input type="checkbox"/> Air District	<input type="checkbox"/> MRWPCA	<input type="checkbox"/> DFG	<input type="checkbox"/> NOAA
<input checked="" type="checkbox"/> Cal-EMA	<input type="checkbox"/> FED EPA	<input type="checkbox"/> DHS	<input checked="" type="checkbox"/> Health Officer	<input type="checkbox"/> OSPR

**Narrative:** The Monterey County Environmental Health Bureau received a CalOES report regarding a PG&E transformer leaking FR3 (Non-PCB) insulating oil onto the ground and running into an agricultural canal that has stagnant water. I contacted the reporting party, Caren Wilhoit from PG&E, on Monday, August 14<sup>th</sup>, and she indicated that they have a contractor ready to do the cleanup. I checked with Caren again today (August 18) to check on the status of the cleanup, she indicated that the farm operator would not allow their trucks onto the property since it is too wet and muddy. PG&E had the contractor use absorbent pads to remove the sheen on the water but were unable to continue with the cleanup until the property dries. I will continue to follow up with PG&E until the cleanup has been completed.

**Incident Status:**

Mitigated No Further Action       Health Department Follow-up Warranted


Referred to other Agency or Department for follow-up:

Contact information:

Action taken:

Form Completed By:       8/18/23  
 Donn Poticar, R. E. H. S. III      Date

*FOR LOCAL AGENCY USE ONLY*  
 I HEREBY CERTIFY THAT I AM A DESIGNATED GOVERNMENT EMPLOYEE AND THAT I HAVE REPORTED THIS INFORMATION TO LOCAL OFFICIALS PURSUANT TO SECTION 25180.7 OF THE HEALTH AND SAFETY CODE.

      8/18/2023  
 Randy McMurray, R. E. H. S. IV      Date  
 Supervising Hazardous Materials Specialist

**ACTIVITY LOG**

Date	Activity	Specialist	Start	Stop	Total
8/14/23	Communication	D. Poticar	1:30 PM	2:00 PM	0.5 Hr
8/18/23	Report Writing	D. Poticar	4:30 PM	5:00 PM	0.5 Hr
<b>**make your selection** - TOTAL:</b>					1.0 Hr

**MCHD** 23- 068 ,  
**CM024-00145**