

MCHD 23-099

**Governor's Office Emergency Services
Hazardous Materials Spill Report**

DATE: 10/20/2023 TIME: 1526	RECEIVED BY:	CONTROL#: Cal OES - 23-6655 NRC -
--	---------------------	--

1.a. PERSON NOTIFYING Cal OES:

1. NAME: **2. AGENCY:** **3. PHONE#:** **4. Ext:** **5. PAG/CELL:**
 Monterey Regional Fire

1.b. PERSON REPORTING SPILL (If different from above):

1. NAME: **2. AGENCY:** **3. PHONE#:** **4. Ext:** **5. PAG/CELL:**

2. SUBSTANCE TYPE:

2. a.	b.QTY: >=<Amount	<i>Measure</i>	c. TYPE:	d. OTHER:	e. PIPELINE	f. VESSEL
SUBSTANCE:						>= 300 Tons
1. Sewage	=	5-10	Gal(s)	SEWAGE	No	No
2.	=				No	No
3.	=				No	No

g. DESCRIPTION:

RP states they responded to a report of a sewage leak coming from a 2 story commercial office building. Fire Department is on scene confirming there is an overflow from the sewage access pipe to a building. The pumps have stopped working causing the overflow. Material is flowing into an release gutter that is flowing into a unknown creek behind business that has standing water in it; estimated current flow appears slow, similar to a slow rate that a garden hose would put out. The City of Monterey Public Works is on scene to secure and mitigate. Cal America Water company is also on scene working on repairing the failed pumps that caused the blockage. The stagnant water creek leads to an old, dried out pond, RP does not see any wildlife around the stagnate creek or any fish. RP contacted the owner of the business, she stated they had previously had an issue with toilet back up in the business that had caused a similar issue. At this time an estimated 5-10 gallons has made it into the creek. There is a city environmental health employee on site who conducted a test on the material and indicates a "moderate" ammonia test of 2 parts per million.

h. STOPPAGE/CONTAINMENT: **i. WATER INVOLVED:** **j. WATERWAY:** **k. DRINKING WATER IMPACTED**

Not stopped, Not contained Yes Unknown Creek No

l. MARITIME VESSEL **m. KNOWN IMPACT**

No Unknown

3. a. INCIDENT LOCATION: 9600 Blue Larkspur
b. CITY: **c. COUNTY:** **d. ZIP:**
 Unincorporated county area Monterey County 93940 MONTEREY BAY UNIFIED APCD
 Monterey

4. INCIDENT DESCRIPTION:

a. DATE: **b. TIME (Military):** **c. SITE:** **d. REPORTED CAUSE**
 10/20/2023 1425 Merchant/Business Blockage

e. INJURIES **f. FATALITY** **g. EVACUATION** **h. CLEANUP BY:**
 No No No Contractor

6. NOTIFICATION INFORMATION:

a. ON SCENE: **b. OTHER ON SCENE:** **c. OTHER NOTIFIED:**
 Fire Dept., Other Public Works

d. ADMIN. AGENCY: Monterey County Health Department **e. SEC. AGENCY:** **CM024-00333**

f. ADDITIONAL COUNTY: **g. ADMIN. AGENCY:**

h. NOTIFICATION LIST:

Cal GEM:

RWQCB Unit:

3

Cal OES Region:

AA/CUPA, DTSC, RWQCB, US EPA, USFWS, CDPH-D.O., LANDS, PARKS & REC, Co/Hlth, Co/E-Hlth

Photo Attachment:	
-------------------	--

11. Cal OES Reg.

***** **Control No: 23-6655** *****

Created by: Warning Center on: 10/20/2023 03:26:09 PM Last Modified by: Warning Center on: 10/20/2023 03:50:00 PM

MCHD 23-099
CM024-00333