

**Monterey County Health Department
Environmental Health Division
Emergency Response Incident Report
Proposition 65 Notification**

MCHD Log# **20-010**
CO0021624

Incident Date: 2/6/2020		Incident Time: 6:00 AM	
Incident Type:	<input type="checkbox"/> Hazardous Material <input type="checkbox"/> Suspected Bioterrorist Threat <input type="checkbox"/> Clandestine Drug Lab	<input checked="" type="checkbox"/> Sewage <input type="checkbox"/> Restaurant Fire <input type="checkbox"/> Other: _____	
Time Notified: 9:07 AM		Time Completed: 1:48 PM	
Location: Soledad Prison Rd. (Soledad Correctional Training Facility)		City: Soledad	
Hazardous Material: Sewage		Quantity: ~60,000 gallons	
Physical Properties: Greywater, Liquids		Physical / Health Hazards: Biological	
Land Use: N/A	Direct/Constructed Connections Found: N/A	Entered Storm Drain System: No	
Environment Affected: Dirt & Asphalt			Weather / Temperature: 41° F
Type of Container: N/A			
First Responder / Agency on Scene: Water Treatment Sewage Plant Supervisor			
Incident Commander: Water Treatment Sewage Plant Supervisor Refugio Jimenez		Agency / Telephone: (831) 678-3951 ext. 4739	
Other Responding Personnel / Agencies / Telephone:			

Source Investigation Conducted? Yes		Source Identified? Yes	
Responsible Party Information:	Refugio Jimenez (831) 678-3951 ext. 4739		
Vehicle Information:	O.E.S. Control #: 20-0739	NRC #:	

Other Notifications:				
<input checked="" type="checkbox"/> RWQCB	<input type="checkbox"/> Air District	<input type="checkbox"/> MRWPCA	<input type="checkbox"/> DFG	<input type="checkbox"/> NOAA
<input type="checkbox"/> Cal-EMA	<input type="checkbox"/> FED EPA	<input type="checkbox"/> DHS	<input checked="" type="checkbox"/> Health Officer	<input type="checkbox"/>

MCHD#20-010

CO-21624

Narrative: The Health Department was notified of a sewage spill located in Correctional Training Facility five miles north of Soledad, CA. 93960. The spill began at around 6:00 AM. The first responders on scene were the Water Treatment Sewage Plant Supervisor, Fire Department Captain and Chief along with Correctional Training Hazmat coordinator.

Environmental Health conducted site inspection. The spill was immediately re-directed into the percolation/holding ponds on-site. Spill did not reach any body of water or storm drains. The percolation pond was vacuumed and disposed back into manhole to circulate back into wastewater treatment plant. Plant Supervisor determined that a control program unit in the lift station lost power causing the release. Control program unit will be replaced.

On 2/7/2020 Plant Supervisor confirmed the affected top layer of soil will be scraped, bagged, and delivered to the landfill. Area will be disinfected with sodium hypochlorite.

Incident Status:

Mitigated No Further Action

Health Department Follow-up Warranted

Referred to other Agency or Department for follow-up:

Contact information:

Action taken:

Form Completed By:



Edna Botello, EHS III

2/7/2020

Date

FOR LOCAL AGENCY USE ONLY

I HEREBY CERTIFY THAT I AM A DESIGNATED GOVERNMENT EMPLOYEE AND THAT I HAVE REPORTED THIS INFORMATION TO LOCAL OFFICIALS PURSUANT TO SECTION 25180.7 OF THE HEALTH AND SAFETY CODE.



R. Encarnacion, Asst. Dir. for

John Ramirez, MPA, REHS

Director of Environmental Health

2/7/2020

Date

ACTIVITY LOG

Date	Activity	Specialist	Start	Stop	Total
2/6/20	Notification/Communication	E. Botello	9:30 AM	9:45 AM	0.25
2/6/20	On-Site Inspection	E. Botello	12:30 PM	1:48 PM	1.0
2/7/20	Writing Report	E. Botello	11:00 AM	12:00 PM	1.0
Invoice Sent to Responsible Party for Total Hours TOTAL					2.25

MCHD# 20-010

Governor's Office Emergency Services

Hazardous Materials Spill Report CO-21024

DATE: 02/06/2020 TIME: 0907	RECEIVED BY:	CONTROL#: Cal OES - 20-0739 NRC -
--	---------------------	--

1.a. PERSON NOTIFYING Cal OES:

1. NAME: 2. AGENCY: 3. PHONE#: 4. Ext: 5. PAG/CELL:
 Correctional Training
 Facility Soledad

1.b. PERSON REPORTING SPILL (If different from above):

1. NAME: 2. AGENCY: 3. PHONE#: 4. Ext: 5. PAG/CELL:

2. SUBSTANCE TYPE:

2. a. SUBSTANCE:	b. QTY: >=<Amount	Measure	c. TYPE:	d. OTHER:	e. PIPELINE	f. VESSEL >= 300 Tons
1. Sewage	= 60,000	Gal(s)	SEWAGE	No	No	No
2.	=			No	No	No
3.	=			No	No	No

g. DESCRIPTION: Per the caller a control program unit at the lft station failed causing the release. Contained to holding ponds and a small amount on a dirt road

h. STOPPAGE/CONTAINMENT: INVOLVED: Stopped, Contained
 i. WATER: No
 j. WATERWAY: IMPACTED: No
 k. DRINKING WATER: IMPACTED: No

l. KNOWN IMPACT: Signs Posted

3. a. INCIDENT LOCATION: Correctional Training Facility 5 miles North of Soledad on US 101

b. CITY: Unincorporated county area Monterey
 c. COUNTY: Monterey County
 d. ZIP: 93960
 MONTEREY BAY UNIFIED APCD

4. INCIDENT DESCRIPTION:

a. DATE: 02/06/2020	b. TIME: (Military): 0700	c. SITE: Other	d. REPORTED CAUSE: Mechanical
Description for Other : Training Facility			

e. INJURIES: No
 f. FATALITY: No
 g. EVACUATION: No
 h. CLEANUP BY: Reporting Party

6. NOTIFICATION INFORMATION:

a. ON SCENE: b. OTHER ON SCENE: c. OTHER NOTIFIED:
 d. ADMIN. AGENCY: Monterey County Health Department
 e. SEC. AGENCY:
 f. ADDITIONAL COUNTY:
 g. ADMIN. AGENCY:
 h. NOTIFICATION LIST:
 DOG Unit: i. RWQCB Unit: 3

AA/CUPA, DTSC, RWQCB, US EPA, USFWS

Photo Attachment:	
-------------------	--

MCHD# 20-010

CO-21024

***** Control No: 20-0739 *****

Created by: Warning Center on: 02/06/2020 09:07:39 AM Last Modified by: Warning Center on: 02/06/2020 09:14:55 AM