

**Monterey County Health Department
Environmental Health Division
Emergency Response Incident Report
Proposition 65 Notification**

**MCHD # 20-018
C000021664**

Incident Date: 02/24/2020		Incident Time: 12:00PM	
Incident Type:	<input type="checkbox"/> Hazardous Material <input type="checkbox"/> Suspected Bioterrorist Threat <input type="checkbox"/> Clandestine Drug Lab	<input checked="" type="checkbox"/> Sewage <input type="checkbox"/> Restaurant Fire <input type="checkbox"/> Other: _____	
Time Notified: 11:05 AM		Time Completed:	
Location: 18672 COOLIDGE STREET		City: Salinas	
Hazardous Material: SEWAGE		Quantity: 3988 GALLONS	
Physical Properties: LIQUIDS		Physical / Health Hazards: BIOLOGICAL	
Land Use: PUBLIC	Direct/Constructed Connections Found:	Entered Storm Drain System/Receiving Waters: YES	
Environment Affected: ASPHALT			Weather / Temperature: 65°F
Type of Container: N/A			
First Responder / Agency on Scene: CITY OF SALINAS			
Incident Commander: ROBERT REYNA		Agency / Telephone: 831-758-7103	
Other Responding Personnel / Agencies / Telephone:			
() -	() -	() -	

Source Investigation Conducted? YES		Source Identified? YES	
Responsible Party Information:	CITY OF SALINAS MAINTENANCE SERVICES DEPARTMENT 426 WORK STREET SALINAS, CA 93901 (831) -758 7103		
Vehicle Information:	CAL-EMA Control #: 20-1071	NRC #:	

Other Notifications:				
<input type="checkbox"/> RWQCB	<input type="checkbox"/> Air District	<input type="checkbox"/> MRWPCA	<input type="checkbox"/> DFG	<input type="checkbox"/> NOAA

MCHD#20-018 / CO-21064

<input checked="" type="checkbox"/> Cal-EMA	<input type="checkbox"/> FED EPA	<input type="checkbox"/> DHS	<input type="checkbox"/> Health Officer	<input checked="" type="checkbox"/> CDFW
---	----------------------------------	------------------------------	---	--

Narrative:


- Monterey County Health Department was notified of a sewage spill by the City of Salinas Maintenance Services Department.
- Release of sewage, about 3988 Gallons, occurred from a manhole located near 18672 Coolidge Street, Salinas CA. Sewage overflow entered the creek nearby upstream.
- Sewage spill was reported to Department of Fish and Wildlife.
- City of Salinas contained sewage release upon arrival on 2/24/2020 at about 9:00 AM.
- Robert Reyna Person in charge at the time of investigation, stated laboratory analysis of bacteriological samples were submitted to the county laboratory.
- Creek was posted due to a community park being near proximity.
- Creek was vacuumed by City of Salinas Maintenance Services Department and asphalt was disinfected with chlorine bleach and water.
- During follow up inspection contaminated area is dry, clean and sanitized.

Incident Status:

<input checked="" type="checkbox"/> Mitigated No Further Action	<input type="checkbox"/> Health Department Follow-up Warranted
<input type="checkbox"/> Referred to other Agency or Department for follow-up:	
Contact information:	
Action taken:	

Form Completed By:  2/25/2020
Michelle Torres, REHS III Date

FOR LOCAL AGENCY USE ONLY
I HEREBY CERTIFY THAT I AM A DESIGNATED GOVERNMENT EMPLOYEE AND THAT I HAVE REPORTED THIS INFORMATION TO LOCAL OFFICIALS PURSUANT TO SECTION 25180.7 OF THE HEALTH AND SAFETY CODE.

 R. Encarnacion, Asst. Dir. for: 2/25/2020
John Ramirez, MPA, REHS Date
Director of Environmental Health

ACTIVITY LOG					
Date	Activity	Specialist	Start	Stop	Total
2/24/20	Emergency Response	Michelle Torres	1:00 PM	2:30 PM	1.5
2/24/20	Report Writing	Michelle Torres	3:00 PM	4:00 PM	1
2/25/20	Follow up inspection	Michelle Torres	9:00 AM	9:30 AM	.5
Invoice Sent to Responsible Party for Total Hours					
TOTAL					3

Governor's Office Emergency Services

MCHD# 20-018 Hazardous Materials Spill Report CO-21664

DATE: 02/24/2020 TIME: 1157	RECEIVED BY:	CONTROL#: Cal OES - 20-1071 NRC -
--------------------------------	--------------	--------------------------------------

1.a. PERSON NOTIFYING Cal OES:

1. NAME: 2. AGENCY: City of Salinas 3. PHONE#: 4. Ext: 5. PAG/CELL:

1.b. PERSON REPORTING SPILL (If different from above):

1. NAME: 2. AGENCY: 3. PHONE#: 4. Ext: 5. PAG/CELL:

2. SUBSTANCE TYPE:

2. a. SUBSTANCE:	b. QTY: >=<Amount	Measure	c. TYPE:	d. OTHER:	e. PIPELINE	f. VESSEL >= 300 Tons
1. Sewage	= 3200	Gal(s)	SEWAGE		No	No
2.	=				No	No
3.	=				No	No

g. DESCRIPTION: Release was due to a blockage a mainline resulting in the material overflowing out of a manhole, release is stopped and contained. Impacted Santa Rita Creek.

h. STOPPAGE/CONTAINMENT: Stopped, Contained
i. WATER INVOLVED: Yes
j. WATERWAY: Santa Rita Creek
k. DRINKING WATER IMPACTED: No

l. KNOWN IMPACT: None

3. a. INCIDENT LOCATION: 18672 Paylor Street, Cool Ridge Street

b. CITY: Salinas
c. COUNTY: Monterey County
d. ZIP: MONTEREY BAY UNIFIED APCD

4. INCIDENT DESCRIPTION:

a. DATE: 02/24/2020
b. TIME: 0950 (Military)
c. SITE: Residence
d. REPORTED CAUSE: Overflow

e. INJURIES: No
f. FATALITY: No
g. EVACUATION: No
h. CLEANUP BY: Reporting Party

6. NOTIFICATION INFORMATION:

a. ON SCENE: Co Health
b. OTHER ON SCENE:
c. OTHER NOTIFIED:

d. ADMIN. AGENCY: Monterey County Health Department
e. SEC. AGENCY:

f. ADDITIONAL COUNTY:
g. ADMIN. AGENCY:

h. NOTIFICATION LIST:
DOG Unit:
i. RWQCB Unit: 3

AA/CUPA, DTSC, RWQCB, US EPA, USFWS, DFG-OSPR, LANDS, PARKS & REC, Co/Hlth, Co/E-Hlth

Photo Attachment:	
-------------------	--

***** Control No: 20-1071 *****

MCHD#20-018

CO-21664

Created by: Warning Center on: 02/24/2020 11:57:33 AM Last Modified by: Warning Center on: 02/24/2020 12:01:40 PM